

Configuration summary

Mat. no.	Description Order code	Quantity	Unit
51001023	**iTEMP TMT182, Head Transmitter HART TMT182-BBAAB	1	ST

010	Approval:	B	ATEX II1G Ex ia IIC T4/T5/T6
020	Configuration Connection:	B	Factory setup Pt100 3-wire 0-100oC, non-SIL
030	Configuration Sensor Type:	A	Factory setup Pt100 3-wire 0-100oC
040	Configuration:	A	Factory setup Pt100 3-wire 0-100oC
050	Additional Option:	B	Works calib. certif., 6-point, DIN mounting set